

Handled by, department
Joel Blom
Fire Technology
+46 10 516 56 93, joel.blom@sp.se

Date
2009-11-30
Rev.date
2010-06-18

Reference
P906047 A

Page
1 (1)

Kaso Oy
Lyhtytie 2
00750 Helsinki
Finland

Statement concerning Kasos PK-400 series cabinets

Products

Fire resistant filing cabinets:

Cabinet models	External dimensions (mm)			Internal dimensions (mm)			Weight (kg)
	width	height	depth	width	height	depth	
PK-410	666	673	574	486	493	364	151
PK-420	666	1023	574	486	843	364	203
PK-430	666	1373	574	486	1193	364	257
PK-440	666	1723	574	486	1543	364	313
PK-480	1152	1723	574	972	1543	364	493
PK-490	1220	1973	574	1040	1793	364	565

Fire technical classification:

NT FIRE 017 – 120 Paper

The classification for PK-410 to PK-490 is under the assumption that the construction of the cabinets is identical to the tested cabinet.

Statement based on:

Test report P503724, dated November 23, 2005 from SP.

Certificate No. 16 49 06 from SP.

SP Technical Research Institute of Sweden Fire Technology - Fire Resistance


Joel Blom
Technical Officer


Lars Boström
Technical Manager

SP Technical Research Institute of Sweden

Postal address
SP
Box 857
SE-501 15 BORÅS
Sweden

Office location
Västeråsen
Brinellgatan 4
Borås

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@sp.se

This document may not be reproduced other than in full, except with the prior written approval of SP.